



Performance Test Certificate

Issued To

**GAMMA LINE INTERNATIONAL
P.O. BOX 92833, RIYADH 11663
KINGDOM OF SAUDI ARABIA**

Intertek has tested representative samples of
Gamma Line International
4 Way Throw GSD Square Diffusers

4 Way Throw GSD Square Diffusers (150, 225, 300, 375, 450, 525 and 600mm.) were tested
in accordance with the standards listed below and were found
to perform in a manner appropriate to the dictates of the standards.

STANDARDS

ASHRAE 70-1991 "Method of Testing for Rating
the Performance of Air Outlets and Inlets"

ADC 1062: GRD-84 "Test Code for Grilles, Registers and Diffusers"

SCOPE OF TESTING

The diffusers were tested for the following performance characteristics:
"Reference Intertek Report Number 3102706CRT-001 dated October 31, 2006"

- A) Sound Power Level ((NC)
- B) Air Velocity versus Static Pressure
- C) Area Factor
- D) Throw Pattern

Date: June 13, 2011

A handwritten signature in black ink that reads "James R. Kline".

James R. Kline
Intertek
Engineer / Quality Supervisor

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.